CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

GHOSH METAL INDUSTRIES LLC

P.O Box: 23643 ,Plot No 0873, Unit No: 1, Um Laob Area, , Umm Al Quwain, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 13165:2012+A2: 2016

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



ENG. MAJED AL SHAMSI
Certification and Quality Control of Products Section's Manager
Dubai Central Laboratory Department-Dubai Municipality

CB-PRD-001

Certificate No: CL22020808
Valid Until: 27/06/2027

PRODUCT CONFORMITY

Current Issue Date: 28/06/2026
Original Issue Date: 28/06/2022

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL22020808

Certificate Issued To: **Ghosh Metal Industries LLC**
P.O Box: 23643 ,Plot No 0873, Unit No: 1,
Um Laob Area, , Umm Al Quwain, UAE

Applicable Standard Specification: **BS EN 13165:2012** : BS EN 13165:2012+A2: 2016 Thermal Insulation Products for Buildings Factory Made Rigid Polyurethane Foam (PU) products –Specification..

Applicable Specific Rules: **DM-DCLD-RD-DP21-2124 (IC)** : Certification of Factory Made Polyurethane Rigid Foam Thermal Insulation as per BS EN 13165:2012+A2:2016.

S/N	Product Description	Brand Name	Product Details
1	Factory-made polyurethane (PUR) foam AND rigid polyisocyanurate (PIR) foam CFC Free (**See Note 4**)	GMI	Nominal Thickness (min) – 25 mm Length (min) – 0.3 meters; Width (min) – 1.0 meters; Apparent Density = 35 kg/m³ (min); Thermal conductivity (Max) - 0.025 W/(m*K) @ 35C & 60% RH Water vapor transmission MU= 50 to 150 Dimensional Stability = DS(TH) 1 &DS (70,90) L&W <5 T<10 Code : PIR/PUR-EN 13165-T1-DS(TH)1-CS(10/Y)100- MU50-150 Manufactured with either aluminum foil facing or flat or corrugated metal sheet on both or either side to be used as thermal insulation sandwich panel.

OPEN DATA بيانات مفتوحة

DUBAI CENTRAL LABORATORY DEPARTMENT

DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION

FOR CERTIFICATE NO. CL22020808

NOTE 1: This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCLD Conformity Mark.

NOTE 3: As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end user of the product (if needed).

NOTE 4: CFC Free as per declaration from the company, in accordance with the Al Saafat Dubai Green Building System.

NOTE 5: In accordance with Dubai Municipality requirements, any mandatory product manufactured in a certified factory and not covered under the approved scope of certification shall not be distributed, sold, or used within the Emirate of Dubai.

Original Issue Date : 28-06-2022

Current Issue Date : 28-06-2026

Valid Until : 27-06-2027



ENG. MAJED AL SHAMSI

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION'S MANAGER

OPEN DATA بيانات مفتوحة